

Ouneva Oy affirms that this equipment has been designed and manufactured in accordance with the directive 2014/34/EU.

The equipment has been tested and certified issued by:

Eurofins Expert Services Oy  
Kivimiehentie 4, Espoo  
P.O. Box 47,  
FI-02151 Espoo,  
FINLAND  
(Notified Body number 0537)


This declaration is based on compliance with relevant parts of following standards:

EN 60079-0 (2012) /A11 (2013)  
EN 60079-7 (2015)  
EN 60079-31 (2014)

This equipment has been marked with CE marking. All boxes have class IP66 protection. We confirm that the products manufactured by Ouneva Oy fulfill the requirements of the directive 2011/65/EU (RoHS II) and directive 2015/863 (RoHS III)


**Product(s):** CABLE TERMINAL BOXES  
**Type(s):** C, D and D2

**Reference:** VTT 07 ATEX 091X Issue 1

**Marking:** CE 0537   II 2 GD Ex eb IIC Gb  
Ex tb IIIC Db  
IP66

Ouneva Oy

Date



51 2 20 20

Aaro Väänänen  
Quality Engineer/ATEX Respondent