



RADE KONČAR - KONTAKTORI I RELEI d.o.o.

III Makedonska brigada br.54, 1000 - Skopje, MAKEDONIJA
telefon / faks: ++389 2 24 61 106, 2463 596
<http://www.radekoncar.com.mk>



DECLARATION OF CONFORMITY

Nº: RK9-F

We, RADE KONČAR – Kontaktori i relei d.o.o

III Makedonska brigada br.54, Skopje , Makedonioja Tel.++389 2 2461 106

Declare under our sole responsibility that our products described below can be installed, maintained and used in the application for which are made, with respect of the “professional practices”, relevant installation standards and manufacturer’s instructions.

TYPE OF PRODUCTS: Moulded case circuit breakers

| Type | In | Ue | Icu/Ics | pole |
|------------|--------------|------|---------|------|
| KP 125-F | (16-125)A | 415V | 25/18kA | 3/4 |
| KP 250-F | (160-250)A | 415V | 35/35kA | 3/4 |
| KP 800-F | (300-630)A | 415V | 50/25kA | 3 |
| KP 800-F | (800)A | 415V | 50/50kA | 3/4 |
| KP 800-FE | (300-800)A | 415V | 50/50kA | 3/4 |
| KP 1250-FE | (1000-1250)A | 415V | 50/25kA | 3/4 |
| KP 1600-FE | (1000-1600)A | 415V | 50/25kA | 3 |
| KP 2500-FE | (2000-2500)A | 415V | 50/50kA | 3 |

CONFORMITY WITH STANDARDS: EN 60947-2 : 2006/A2:2013

The products are complying with the **PROVISION OF COUNCIL DIRECTIVES:**

- 2014/35/EU - Low Voltage Directive (LVD)
- 2014/30/EU - Electromagnetic Compatibility (EMC)

On the basis of this declaration, the products and the packaging will bear the following

marking **CE**

Skopje, 31.08.2022



Quality control department

Manager,

Zoran Gjorgjievski, dipl.el.ing